


### VALUE TEST™ EXHAUST FAN MODELS 696NC & 695C



**Quiet, high performance fan with a modern styled, low profile grille.**

**FEATURES**

**GRILLE:**

- Torsion mounting - no tools required
- White polymeric matches any decor

**BLOWER:**

- Plug-in permanently lubricated motor, requires no maintenance
- Impellor based blower system provides a high capacity air flow
- Low RPM for quiet performance
- Dynamically balanced impellor based blower system provides high efficiency

**HOUSING:**

- Built-in mounting ears
- Compact size facilitates installation between framing members
- Galvanized steel housing
- Ceiling or wall installation
- Tapered 3" (76.2 mm) round, polymeric duct connector - prevents metallic clatter

**TYPICAL SPECIFICATION**

Ventilator shall be NuTone Model 696NC or 695C.

Ventilator shall have steel housing. It shall be ducted to a roof or wall cap using 3" (76.2 mm) round ductwork. Automatic back draft damper shall be located within duct connector.


Blower assembly shall be impellor based and have a permanently-lubricated motor. Blower shall also operate at a low RPM rating.

Air delivery shall be no less and sound levels no greater than listed. All air and sound ratings shall be certified by HVI. Units shall be CSA certified.


**SPECIFICATIONS**

MODEL	VOLTS	AMPS*	Hz	SONES	CFM (L/s)	DUCT (Round)
696NC	120	1.1	60	3.0	50 (23.6)	3" (76.2mm)
695C	120	1.5	60	5.5	70 (33.0)	3" (76.2mm)

\*Total Connected Load



HVI-2100 CERTIFIED RATINGS comply with the new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.1 in. static pressure, based on tests conducted in AMCA's state-of-the-art laboratory. Sones are a measure of humanly produced loudness, based on laboratory measurements.



Broan-NuTone Canada Inc., Mississauga, Ontario, Canada L5T 1H9

REFERENCE	QTY.	REMARKS	Project
			Location
			Architect
			Engineer
			Contractor
			Submitted by <span style="float: right;">Date</span>